

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 352

Dated: 14/07/2025

It is certified that an inspection team headed by Mr. D.P. Singh Lab. Incharge/Sub Eng.  
 (Name of Officers with designation) from Mrs. Anita Jayant chemist  
 (Name of Department/ Office) inspected the Public Health Engineering Department on  
 (Name & Address of the school) on 11/07/2025 (date of inspection) and found that the  
Wellington World School Sataul (Name of school) has safe drinking water  
 facilities for the students and members of staff of the institution and is maintaining the hygienic  
 sanitation condition in the school building & the campus as per norms prescribed by the Central/  
 State/ U.T. Govt.

The above is valid for a period of

One year [14/07/2025 to 13/07/2026]OTB/26  
Lab InchargeSignature with Seal D.P. Singh District Water Testing Laboratory  
P.H.E. Division, Gwalior (M.P.)

Name

D.P. Singh

Designation

Sub Engineer/Lab. InchargeName & Address of the Office / Department P.H.E.D Gwalior

To

Principal

Wellington World School  
New Shivpuri Link Highway village Sataul  
 (Name & Address of the Institution) Gwalior (M.P.)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

**Public Health Engineering Department District Water- Testing  
Laboratory Gwalior**  
**Test Report**

Type of sample: Water Sample		Particular of sample : collected / not collected by PHED	
Particular of sender:- Principal Wellington World School , New Shivpuri Link Highway Village Satau Gwalior ,M.P.			
Sample No.	Place of Collection and Details of Sample		Date of collection
1	Drinking Water		08.07.2025
2	-		-
3	-		-
4	-		-
Particular of Sample :			
Date of Receipt:- 08.07.2025		Time of Receipt: 12:40 PM	
Lab Reference No:		Date of Analysis:- 09.07.2025	

**Nature of Study – Chemical and Bacteriological Analysis**

S.N.	Characteristics	Unit	As Per BIS-10500-2012 For Drinking Water		RESULT			
			Acceptable Value	Permissible limit in the absence of alternate source	Sample 1	Sample 2	Sample 3	Sample 4
<u>PHYSICAL TESTE</u>								
1	Turbidity	NTU	1.0	5.0	02	-	-	-
2	Color	Cobalt	5	15	-	-	-	-
3	Taste & Odour		Unobjectionable	Objectionable	Unobjectionable	-	-	-
4	Temperature	C°	-	-	-	-	-	-
<u>CHEMICAL TESTE</u>								
5	PH Value	PH Scale	6.5 To 8.5	No Relaxation	7.5	-	-	-
6	Alkalinity	Mg/L	200	600	204	-	-	-
7	Chlorides (as Cl)	Mg/L	250	1000	55	-	-	-
8	Nitrate as No3	Mg/L	45	45	10	-	-	-
9	Total hardness	Mg/L	200	600	300	-	-	-
10	Calcium as Ca	Mg/L	75	200	72	-	-	-
11	Magnesium as mg	Mg/L	30	100	29	-	-	-
12	Iron	Mg/L	0.3	1.0	0.18	-	-	-
13	Free Chlorine	Mg/L	0.2	1.0	0.0	-	-	-
14	T.D.S.	Mg/L	500	2000	383	-	-	-
15	Fluoride	Mg/L	1.0	1.5	0.16	-	-	-
16	Sulphate sa SO4	Mg/L	200	400	12	-	-	-
<u>BECT. FEACAL TESTE</u>								
17	MPN of coliform	per 100 ml	Nil		-	-	-	-
18	Faecal Coliform	Per 100 ml	Nil		Nil	-	-	-

1. This report should not be provided partially or fully without approval of signatory authorities for legal purposes.
2. It is Recommended that acceptable limit is to be implemented values in excess those mentioned under " Acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source, but up to the limits indicated under the "permissible limit in the absence of alternate Source"
3. The results refer only to tested samples and parameters tested.
4. samples will be stored for a period of 10 days from the date of issue of report.
5. This Lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.

Signature of Analyst  
District Water Testing Lab  
P.H.E. Division Gwalior

Lab Incharge  
District Water Testing Laboratory (M.P.)  
P.H.E. Division, Gwalior (M.P.)

No. 352 /PHED/ Date :- 14/07/2025